



The Road Less Traveled: 144" Gravity Sewer Tunnel in DOT ROW

Gail Hamrick-Pigg, P.E. | Director, Engineering Pipelines, SAWS
Jeff Farnsworth, P.E. | Project Manager, Kimley-Horn





Agenda

- Project History
- Alignment/Overview
- Tunnel Reaches
- TxDOT Approvals
- Other Approvals/Coordination
- Contractor Outreach
- Geotechnical Considerations
- Tunnel Construction
- Shaft Construction

Project Background/History

- SAWS Initiated design work in 2007
- Challenges
 - Personnel Changes
 - Former closed landfills
 - Easement terms
 - Risk allocation
 - Alternative alignments
- Congressional action triggered resolution
 - National Defense Authorization Act for FY 2019
 - MOA with USAF Executed August 2019




Alignment Overview

- Western Sewershed, along US 90 and W. Military Dr
- Pipe Diameter and Segment Length
 - 26,000 LF of ~144" tunnel in Navarro Group and Marlbrook Marl formations
 - 2,500 LF of ~78" tunnel construction
 - Installation along TXDOT right-of-way
 - Eight shaft locations
 - Solids Removal Structure




Design Schedule

- NTP – February 2019
- 30% Verification – May 2019
- 60% Design – Sept 2019
- 90% Design – November 2019
- 100% Design – January 2020
- Bid – February 25, 2020
- Construction NTP – July 1, 2020



Tunneling Reaches

- Construction Sequencing



TxDOT Approvals

- UIR
- Driveway permit



Other Approvals - DoD

- Memorandum of Agreement (Act of Congress)
- Structural Analysis
- Coordination Meetings
- Fence Relocations
- Abandonment

Other Approvals - CPS Energy

- Gas Coordination (shafts)
- Electric Power Coordination
- Shafts that will utilize generator to supply power to site:
 - Callaghan Shaft
 - Ball Park Shaft
 - W-1 Connection Shaft

BRIERLEY ASSOCIATES
Creating Space Underground

MEMORANDUM

DATE: 10/8/2019

TO: Kimley-Horn Associates

FROM: Brierley Associates

SUBJECT: SAWS W-6 Upper Segment – Tunnel and Shaft Power Requirements

This memorandum details the general power requirements for the SAWS W-6 Upper Segment Project. These are meant to be general recommendations to be used for planning and running power to each shaft site. The actual contractor's needs may vary, and they may opt to utilize isolated diesel generators where necessary.

TBM Power Requirements: Two Tunnel Boring Machines (TBM) are anticipated to be utilized which typically may be outfitted with approximately four 250 HP motors requiring a peak power demand of 746 kW. The trailing equipment will also require power up to 600 HP peak demand requiring up to 448 kW. The TBM power requirements may be upwards of 1194 kW total.

Microtunnel Operations: It is anticipated that the MTBM section will be powered using localized generators and will be left solely up to the contractor.

Ventilation Power Requirements: Ventilation systems will be required along each tunnel drive consisting of a main fan with intermediate booster fans on the main drives. The combined power demand on the ventilation system may be upwards of 373 kW but will vary per drive.

Conveyor Systems Power Requirements: A conveyor system may be opted to be used by the contractor on the longer drives to save in efficiency of muck removal operations. Intermediate boosters will likely be required due to the length of some of the drives. Approximately 746 kW is required for the primary and booster stations.

Lighting and Communications Power Requirements: Underground lighting and communications with the TBM and personnel will require power as well. These items are generally low in power demand but will total approximately 67 kW to power these systems.

Dewatering Power Requirements: Dewatering operations may or may not be required depending on how design progresses for the shafts and requirements for treatment of groundwater dependent on the Phase II ESA. Currently water tight shafts are planned which will only require pumping from within the shaft itself during excavation of the shaft. If other initial support systems, such as ring beams and lagging or liner plate and ring beams are utilized additional dewatering wells may be required to pump up to 10-15 gpm. Power demand for water tight shafts will just be limited to several sump pumps. For a full dewatering system power demand may reach up to a peak of 56 kW.

Other Approvals - TCEQ

- Environmental Testing and Manifest Requirements:
 - Material Type
 - Amount per Truckload
 - Disposal Locations

Contractor Outreach

- 96 people in attendance
- More than a dozen prime contractors

W-6 Upper Segment: Highway 90 to SW Military Drive Sewer Main Project

Gail Hamrick-Pigg, P.E.

Director, Engineering Pipelines, SAWS

Diana L. Woltersdorf

Manager, Contract Administration, SAWS

Marisol V. Robles

SMWVB Program Manager, SAWS

Jeff Farnsworth, P.E.

Project Manager, Kimley-Horn and Associates, Inc.

Kevin Mandeville, PG

Geologist, Brierley Associates

Fred Flores

Contract Administrator




Contractor Outreach


October 18, 2019


MAKING SAN ANTONIO
WATERFUL

Geotechnical Considerations

- 60 Borings (150-ft depth)
- Geophysical Study
- Groundwater
- Faults
- Sticky Clay
- Naturally Occurring Hydrocarbons
- Geotechnical Baseline Report
- Geotechnical Data Report








Typical Shaft Design

- Value Engineering
- Polymer Concrete
- 3 Piece Shaft Lid



Tunnel Design

- ~144" Tunnel with 104" Carrier Pipe
- 2 TBMs (Schedule / Geology)
- EPBM Open Face / EPBM Dual Mode
- Maximum Tunnel Curvature (1200' radii)

- Design currently being finalized
- Release for Bid – February 25, 2020
- Board Award – June 2020
- Construction NTP – July 2020

See you next year, for a Construction Update...



Questions?

Shaft 6: W-1 Connection Shaft

