



**UNDERGROUND CONSTRUCTION TECHNOLOGY**

THE UNDERGROUND UTILITIES EVENT | JANUARY 25-27, 2022 | FORT WORTH, TEXAS

# Pipeline Construction Inspection Guidelines

Greg Scoby, PE

President

Crossbore Consultants



## Presentation Goals

Re-inforce importance of:

- Collecting records before assets are buried
- Verifying all materials meet specifications
- Verifying that installers are qualified for work specified
- Verifying that fabrication equipment/tooling is capable/functional
- Capturing images for future maintenance activity
- Knowing underground location (GPS) of all fittings, pipe alignment, etc.
- Uploading all of the above information into a Geographical Information System (GIS)



16" HDPE Water Main Fabrication



# UNDERGROUND CONSTRUCTION TECHNOLOGY

THE UNDERGROUND UTILITIES EVENT | JANUARY 25-27, 2022 | FORT WORTH, TEXAS

## Municipal Advisory Board (MAB)

<https://plasticpipe.org/MunicipalAdvisoryBoard?hkey=0332405c-e02d-4c01-969e-2a3d42c2a58b>

- Group of water distribution companies/Cities nationwide
- User Members have realized the benefits of HDPE water systems
- User Members concerns addressed by prioritizing document development
- Task Group teams formed of User Members, manufacturers and consultants for each document produced

### Who Has Been Affected






## MAB Accomplishments

<https://plasticpipe.org/MunicipalAdvisoryBoard?hkey=0332405c-e02d-4c01-969e-2a3d42c2a58b>

- MAB -1: Generic Electrofusion Procedure for Field Joining of 12 inch & Smaller Polyethylene Pipe ( $\leq 305\text{mm}$ )
- MAB-2: Generic Electrofusion Procedure for Field Joining of 14 inch to 30 inch Pipe (355mm-762mm)
- MAB-3: Model Specification for PE 4710 Buried Potable Water Service, Distribution and Transmission Pipe & Fittings
- MAB-4: Basic HDPE Repair Options
- MAB-5: Guidelines for PE 4710 Pipe Bursting of Potable Water Mains
- **MAB-6: Guidelines for HDPE Pipeline Inspection**
- MAB-7: Guidelines for Use of Mini-Horizontal Directional Drilling for Placement of HDPE (PE4710) Pipe in Municipal Applications



MAB – 6 Guidelines for HDPE Pipeline Inspection



## MAB-6 Document

[https://plasticpipe.org/Shared\\_Content/Publications/MAB-Publications/MAB-6-Main.aspx](https://plasticpipe.org/Shared_Content/Publications/MAB-Publications/MAB-6-Main.aspx)

(intended for field use by providing forms for documentation)

- Introduction
- Appendix A – HDPE Material Inspection Forms
- Appendix B – HDPE Equipment Qualification Forms
- Appendix C – HDPE Connection Inspection Forms
- Appendix D – HDPE Pressure Testing Form
- Appendix E – Other Sources of Information



14" Butt Fusion/MJ Joint Adapter Fitting



# UNDERGROUND CONSTRUCTION TECHNOLOGY

THE UNDERGROUND UTILITIES EVENT | JANUARY 25-27, 2022 | FORT WORTH, TEXAS

## Appendix A -HDPE Material Inspection Forms

- Pipe
- Molded and Fabricated Fittings
- Electrofusion Fittings
- Mechanical Fittings



Project HDPE Pipe Storage - 8", 12", 14", 16"

**MAB-6 APPENDIX A: HDPE INCOMING MATERIAL INSPECTION/QC FORM**

Project Name: \_\_\_\_\_ Project Number: \_\_\_\_\_  
Inspector Name: \_\_\_\_\_ Employee Number: \_\_\_\_\_  
Date: \_\_\_\_\_

---

**PIPE**

All of the following data is available in the print line of the pipe. (One form should be completed for each pipe OD delivered)

Pipe Supplier/Vendor Name: \_\_\_\_\_

Manufacturer Name: \_\_\_\_\_ Manufacturer Date: \_\_\_\_\_

Manufacturing Standard:  C906 (AWWA)  C901 (AWWA)  Other (ex. ASTM F714)

Material Certification:  NSF 61  Other \_\_\_\_\_

Type of HDPE Material:  PE4710  Other \_\_\_\_\_

Diameter Sizing:  CTS  DIPS  IPS  Other \_\_\_\_\_

Pipe OD: \_\_\_\_\_ inches

Pipe Pressure Class (PSI)/SDR:  250/9.0  200/11.0  160/13.5  125/17  Other \_\_\_\_\_

See Appendix F for pipe dimension standards.

Pipe Packaging:  Coil Length of coil \_\_\_\_\_  
 Straight Lengths- Individual Length:  40ft  50ft  Other \_\_\_\_\_

Total Length Delivered: \_\_\_\_\_ ft

Damage:

Manufacturing Defect:  Out of tolerance OD  
 Out of tolerance ID  
 Charred material in pipe  
 Voids/ Inclusions/ Non-uniformity/ inconsistent pigmentation  
 Mismatching  
 Other: \_\_\_\_\_

Handling/Shipping:  Scratching/ Gouging/ Other defects  
 Strapping (band damage)  
 Lifting equipment damage  
 Missing end caps

Amount of Pipe Rejected: \_\_\_\_\_ ft  
Amount of Pipe Accepted: \_\_\_\_\_ ft

A 1



## Appendix B – HDPE Equipment Qualification

- Conventional Heat Fusion
  - Socket Fusion
  - Sidewall Fusion
  - Butt Fusion (hydraulic & manual)
- Electrofusion
  - Couplings
  - Sidewall
- Generator
- Ancillary Tooling (peelers, alignment clamps, etc.)



Typical Tooling Required For EF Saddle Installation

**MAB-6 APPENDIX B: HDPE EQUIPMENT QUALIFICATION**

Project Name: \_\_\_\_\_ Project Number: \_\_\_\_\_  
Inspector Name: \_\_\_\_\_ Employee Number: \_\_\_\_\_  
Contractor Name: \_\_\_\_\_ Contractor Contact #: \_\_\_\_\_  
Date: \_\_\_\_\_

**GENERATOR**

Make/ Manufacturer: \_\_\_\_\_ Model: \_\_\_\_\_ Serial Number: \_\_\_\_\_  
Output Capacity: \_\_\_\_\_ Last Recorded Maintenance Date: \_\_\_\_\_  
Verification Method of Output: \_\_\_\_\_ Date: \_\_\_\_\_

Caution: Welding generators are not recommended as power supply for fusion.

Does the generator meet the minimum requirements of the equipment to be powered?  
 Yes  No

The following Tag should be attached to all generators used to power HDPE fusion equipment for field employees/inspectors to verify qualification for the specific generator in use. Consideration should be used for the Tag material which will last for the duration of the project (plastic coated, plastic, water proof).

Sample Tag

<b>Qualified Generator</b> (Company/Owner Name Here)	
Make: _____	Model: _____
Serial Number: _____	
Qualification Number: _____	
Qualification Date: _____	
Employee Issuing Qualification: _____	
Employee Number: _____	
<input type="checkbox"/> (hole for zip tie attachment)	

There are multiple sources of generator testing equipment available; one source is: [https://www.sotcher.com/Load\\_Bank\\_Generator\\_Test\\_Sets/](https://www.sotcher.com/Load_Bank_Generator_Test_Sets/)



## Appendix C – HDPE Connection Inspection Conventional Heating Forms

- Butt Fusion (manual or hydraulic)
  - Tooling review
  - Fusion Technician Qualification
  - Interfacial pressure
  - Iron temperature verification
  - Heating time
  - Bead size/uniformity



14" Butt Fusion

### MAB-6 APPENDIX C: HDPE CONNECTION INSPECTION FORM

Project Name: \_\_\_\_\_  
 Project Number: \_\_\_\_\_  
 Inspector Name: \_\_\_\_\_ Employee Number: \_\_\_\_\_  
 Contractor Name: \_\_\_\_\_ Contractor Contact#: \_\_\_\_\_

#### MANUAL BUTT FUSION

Did the operator complete an inspection of equipment for cleanliness and proper operation?	Yes	No
Did the operator clean pipe ends?	Yes	No
Were the pipe ends faced to the facer stops?	Yes	No
Did the facer stop rotating before the jaws were opened?	Yes	No
Were shavings and chips removed after facing pipe?	Yes	No
When pipe ends were brought together under facing pressure, were visual gaps observed?	Yes	No
Did the operator check alignment of pipe ends?	Yes	No
Was the operation checked for pipe slippage at fusion pressure and pipe ends kept closed?	Yes	No
Was a torque wrench adaptor and torque wrench used?	Yes	No
What was the calculated pressure?		
What was the applied torque?		
Was the heater cleaned and the surface temperature checked with a pyrometer?	Yes	No
What was the observed pyrometer temperature reading?		
Was the pipe seated against the heater properly?	Yes	No
Was pressure relieved for the heat soak time?	Yes	No
Was the carriage lock engaged?	Yes	No
Did the bead size against the heater meet the standard before heater removal?	Yes	No
Was the pipe interfacial area inspected for complete melt after heater removal?	Yes	No
Did the pipe interfacial area appear flat and smooth with no un-melted areas?	Yes	No
Was the heater removal time acceptable in accordance with the Standard?	Yes	No
Is the finished bead size uniform and acceptable in accordance with the Standard?	Yes	No
Completed cooling cycle time (under fusion pressure)	Minutes	Seconds
Was this manual butt fusion joint fabricated with adopted fusion procedure?	Yes	No
Was this manual butt fusion joint accepted?	Yes	No

Installer Name: \_\_\_\_\_ Installer Qualification Date: \_\_\_\_\_

Qualification Issued By: \_\_\_\_\_

Inspector Company: \_\_\_\_\_ Fusion Qualification Date: \_\_\_\_\_

Qualification issued by: \_\_\_\_\_

Inspector Signature \_\_\_\_\_ Date: \_\_\_\_\_

Comments.....



# UNDERGROUND CONSTRUCTION TECHNOLOGY

THE UNDERGROUND UTILITIES EVENT | JANUARY 25-27, 2022 | FORT WORTH, TEXAS

## Appendix C – HDPE Connection Inspection Electrofusion Coupling Form

- Tooling review
- Fusion Technician Qualification
- Fitting used
- Alignment clamps used
- Followed fusion procedures
- Observed recommended cooling time



8" EF Coupling

MAB-6 APPENDIX C: HDPE CONNECTION INSPECTION FORM		
Project Name: _____		
Project Number: _____		
Inspector Name: _____		Employee Number: _____
Contractor Name: _____		Contractor Contact#: _____
ELECTROFUSION COUPLINGS		
Address/Street: _____	Pipeline Station#: _____	Date/Time: _____
Fusion Technician: _____	Company: _____	Employee #: _____
Qualification Issued by: _____	Qualification Issue Date: _____	Qualified Pipe Size(s): _____
Pipe Manufacturer: _____	Manufacture Date: _____	Material Type: _____
EF Coupling Manufacturer: _____	Part #: _____	
Pipe Size: _____	Pipe DR: _____	Description: _____
EF Processor Model: _____	Serial Number: _____	Fusion Number: _____
Generator Make & Model: _____	Serial Number: _____	Rated Capacity: _____
Ambient/Processor Temperature: _____	Weather: _____	Trench Conditions: _____
<b>General:</b>		
Inspect the equipment for cleanliness and proper operation.		
Verify that the generator / power source is adequately sized for coupling being fused.		
Fitting still in undamaged packaging (inspect the fitting for damage through original packaging. Fitting to remain in original packaging until installation).		
Let the EF processor acclimate to the jobsite weather conditions for a minimum period of 15 minutes before beginning the fusion process.		
<b>Couplings:</b>		
Cut pipe ends squarely and evenly (+/- 3 degrees).		
Clean pipe ends of dirt and debris prior to scraping.		
Measure and mark one of the pipe ends for the full length of the coupling. Measure and mark the other pipe end for half the coupling length. Mark the entire pipe area to be scraped with an approved non-petroleum based marker.		
Mount the scraper over the area to be scraped. Scrape the outside of the pipe to remove the surface layer and expose clean virgin pipe beneath. Remark stub depths after scraping.		
Clean surfaces with 99% (or higher) solution isopropyl alcohol & lint-free rag.		
Insert the pipe ends to the stub depth marks. If necessary, a block of wood can be placed over the coupling end and a hammer can be used to drive the coupling onto the pipe. Leave plastic bag over coupler to prevent contamination and debris from entering the open end. Use caution not to damage internal wire or terminal pins.		
Secure assembly with an alignment clamp, with coupling centered between stub depth marks.		
Connect the control box leads to the fitting. Scan the numerical barcode on the fitting using the reader wand on the processor.		
Verify that the fitting was read correctly and initiate the fusion cycle.		
Verify that the EF processor indicated a complete fusion cycle.		
Did the EF processor indicate a cycle failure? If yes, see * below. If no, see ** below.		
*Was the failure due to an input power interruption? If yes, see (A) below. If no, see (B) below.		
Input power interruption examples include the following: (i) fusion leads were detached during fusion, (ii) generator ran out of gas, or (iii) other circumstances that resulted in processor input power interruption.		
(A) If failure was due to an input power interruption, the coupling must be re-fused.		
1. Coupling should remain in restrained position.		
2. Allow the coupling to cool to ambient temperature.		
3. Reconnect coupling to the processor.		
Completely refuse coupling for the entire fusion time.		
(B) Remove coupling that faults for any other reason and install new coupling.		
** Mark on the pipe the fusion cycle end time: _____		Time at end of cooling period: _____
Mark the pipe with the station # and technician name.		Fusion #: _____
Do not remove alignment clamp or rough handle pipe until the proper cooling time (CT) is complete. Rough handling includes moving, backfilling, or pressure testing.		
Was this coupling accepted?		
		Yes <input type="checkbox"/> No <input type="checkbox"/>
Comments: _____		
Inspector Company: _____		Fusion Qualification Date: _____
Qualification issued by: _____		Inspector Signature: _____



## Appendix C – HDPE Connection Inspection Electrofusion Sidewall Form

- Tooling review
- Fusion Technician Qualification
- Fitting used
- Manufacturer specified clamp used
- Followed fusion procedures
- Observed recommended cooling time
- Observed pressure testing of fitting



8" X 1" EF Saddle  
Pressure Tested Before Tapping

MAB-6 APPENDIX C: HDPE CONNECTION INSPECTION FORM			
Project Name: _____		Project Number: _____	
Inspector Name: _____		Employee Number: _____	
Contractor Name: _____		Contractor Contact#: _____	
ELECTROFUSION SIDEWALL			
Address/Street: _____	Pipeline Station#: _____	Date/Time: _____	
Fusion Technician: _____	Company: _____	Employee #: _____	
Qualification Issued by: _____	Qualification Issue Date: _____	Qualified Pipe Size(s): _____	
Pipe Manufacturer: _____	Manufacture Date: _____	Material Type: _____	
Pipe Size: _____	Pipe DR: _____		
EF Saddle Manufacturer: _____	Part #: _____	Description: _____	
EF Processor Model: _____	Serial Number: _____		
Generator Make & Model: _____	Serial Number: _____	Rated Capacity: _____	
Ambient/Processor Temperature: _____	Weather: _____	Trench Conditions: _____	
<b>General:</b>			
Inspect the equipment for cleanliness and proper operation.			
Verify that the generator / power source is adequately sized for saddle being fused.			
Fitting still in undamaged packaging (Inspect the fitting for damage through original packaging. Fitting to remain in original packaging until installation).			
Let the EF processor acclimate to the jobsite weather conditions for a minimum period of 15 minutes before Service/Branch saddles:			
Clean the pipe of dirt and debris prior to scraping.			
Mark the bounds of area to be fused with an approved non-petroleum based marker.			
Scrape the area to be fused with an approved pipe preparation tool.			
Clean the area to be fused with 95% (or higher) solution isopropyl alcohol & lint-free rag.			
Clean the fitting to be fused with 95% (or higher) solution isopropyl alcohol & lint-free rag.			
Secure the saddle to the pipe with the manufacturer recommended clamping mechanism.			
Scan the numerical barcode on the fitting using the reader wand on the processor.			
Verify that the fitting was read correctly and initiate the fusion cycle.			
Verify that the EF processor indicated a complete fusion cycle.			
Did the EF processor indicate a cycle failure? If yes, continue to next step below. If no, see (C) below.			
Was the failure due to an input power interruption? If yes, see (A) below. If no, see (B) below.			
(A) If failure was due to an input power interruption, the saddle must be re-fused.			
(B) Abandon saddle that fails for any other reason and install new saddle.			
(C) Mark on the pipe the fusion cycle end time: _____ Time at end of cooling period _____ Fusion # _____			
Mark the pipe with the house # / tap # and technician name.			
Do not remove saddle clamp or rough handle pipe until the proper cooling time (CT) is completed.			
Rough handling includes moving, backfilling, or pressure testing.			
Perform hydrostatic test after proper cooling time is completed. Test saddle at 200 psi for 5 _____			
Was this saddle accepted? Yes <input type="checkbox"/> No <input type="checkbox"/>			
Comments: _____			
Inspector Company: _____		Fusion Qualification Date: _____	
Qualification issued by: _____		Inspector Signature _____	



## Appendix D – Pressure Testing

- Provided a form for pressure testing documentation
- Based on AWWA M-55 and the City of Fort Wayne, Indiana, USA forms



Hydro Static Pressure Test  
Prior to HDD/Bursting Installation

**MAB-6 APPENDIX D: HDPE PRESSURE TESTING FORM**

Project Name: \_\_\_\_\_  
Project Number: \_\_\_\_\_ Inspector Name: \_\_\_\_\_  
Employee Number: \_\_\_\_\_ Date: \_\_\_\_\_

1. Testing medium (usually water):  Water  Other \_\_\_\_\_
2. Test procedure used:  ASTM F2164  Other \_\_\_\_\_
3. Test Pressure (psig): \_\_\_\_\_
4. Test Duration (hours): \_\_\_\_\_
5. Was all air vented from pipe before testing?  Yes  No
6. Pressure recording chart or pressure log (monitor pressure during expansion and test phases at 15-minute intervals minimum): Time of Day: \_\_\_\_\_ Pressure (PSIG) \_\_\_\_\_
7. Pressure versus makeup water chart (time of day, measure pressure (PSIG), amount of makeup water (gallons):  
Time of Day: \_\_\_\_\_ Pressure (PSIG) \_\_\_\_\_ Makeup Water (gallons) \_\_\_\_\_
8. Pressure at highest location (psig): \_\_\_\_\_ Pressure at lowest elevation (psig): \_\_\_\_\_
9. Elevation at point test pressure is measured (ft): \_\_\_\_\_
10. Ambient Temperature (°F): \_\_\_\_\_ Weather Conditions: \_\_\_\_\_
11. Pipe Manufacturers: \_\_\_\_\_ Valve Manufacturers: \_\_\_\_\_
12. Pipe specifications and/or standards (ASTM, AWWA, etc.): \_\_\_\_\_
13. Test Section Diameter: \_\_\_\_\_ Test Section Length: \_\_\_\_\_  
Location: \_\_\_\_\_ Tested components: \_\_\_\_\_
14. Were all joints exposed?  Yes  No
15. Description of any leaks, failures, and their repair/disposition:  
\_\_\_\_\_
16. Did pressure change less than 5% during test period?  Yes  No
17. Person or Contractor (name) performing test: \_\_\_\_\_

18. Test start time: \_\_\_\_\_ Test completion time: \_\_\_\_\_ Date of test: \_\_\_\_\_

(Modified from AWWA M55, 1<sup>st</sup> Ed., Hydrotesting and Commissioning, Chapter 9, Page 130 and input from the City of Ft. Wayne "Test Procedures for HDPE Pressure Pipe")


D 1





# UNDERGROUND CONSTRUCTION TECHNOLOGY

THE UNDERGROUND UTILITIES EVENT | JANUARY 25-27, 2022 | FORT WORTH, TEXAS

## Appendix E – Other Sources of Information



AWWA M55 2<sup>nd</sup> Edition



### MAB-6 APPENDIX E: OTHER SOURCES OF INFORMATION

#### American Water Works Association, AWWA [www.awwa.org](http://www.awwa.org)

1. ANSI/AWWA C901 Polyethylene (PE) Pressure Pipe and Tubing, 3/4 in. (19 mm) Through 3 in. (76 mm) for Water Service
2. ANSI/AWWA C906 Polyethylene (PE) Pressure Pipe and Fittings, 4 in. Through 65 in. (100 mm) Through 1,650 mm, for Waterworks
3. AWWA M55 PE Pipe—Design and Installation

#### Plastics Pipe Institute, PPI [www.plasticpipe.org](http://www.plasticpipe.org)

1. PPI Handbook of Polyethylene Pipe
2. PPI Polyethylene Piping Systems Field Manual for Potable Water Pipe Sizes and Pressure Classes
3. PPI Position Paper on HDPE (PE4710) Distribution Potable Water Pipe Sizes and Pressure Classes
4. PPI TR-4 PPI Listing of Hydrostatic Design Basis (HDB), Hydrostatic Design Stress (HDS), Strength Design Basis (SDB), Pressure Design Basis (PDB) and Minimum Required Strength (MRS) Ratings For Thermoplastic Piping Materials or Pipe
5. PPI TR-41 Generic Saddle Fusion Joining Procedure for Polyethylene Gas Piping
6. PPI TN-13 General Guidelines for Butt, Saddle and Socket Fusion of Unlike Pipes and Fittings
7. PPI TN-38 Bolt Torque For Polyethylene Flanged Joints
8. PPI TN-46 Guidance for Field Hydrostatic Testing of High Density Polyethylene Pressure Pipelines: Owner's Consideration, Planning, Procedures, and Checklists

#### Municipal Advisory Board, MAB [www.plasticpipe.com/municipal\\_pipe/advisory/](http://www.plasticpipe.com/municipal_pipe/advisory/)

1. MAB-1, MAB Generic Electrofusion Procedure for Field Joining of 12 Inch and Smaller Polyethylene (PE) Pipe
2. MAB-2, MAB Generic Electrofusion Procedure for Field Joining of 14 Inch to 30 Inch Polyethylene (PE) Pipe
3. MAB-3, MAB Model Specifications for PE 4710 Buried Potable Water Service, Distribution and Transmission Pipes and Fittings
4. MAB-4, MAB Basic HDPE Repair Options
5. MAB-5, MAB Guidelines for PE4710 Pipe Bursting of Plastic Water Mains.
6. MAB-6, MAB Guidelines for HDPE Pipeline Inspection

#### NSF International [www.nsf.org](http://www.nsf.org)

- NSF/ANSI 61 Drinking Water System Components—Health Effects


#### ASTM International [www.astm.org](http://www.astm.org)

1. ASTM D2321 Standard Practice for Underground Installation of Thermoplastic Pipe for Sewers and Other Gravity-Flow Applications
2. ASTM D2683 Standard Specification for Socket-Type Polyethylene Fittings for Outside Diameter-Controlled Polyethylene Pipe and Tubing
3. ASTM D2774 Standard Practice for Underground Installation of Thermoplastic Pressure Piping
4. ASTM D3261 Standard Specification for Butt Heat Fusion Polyethylene (PE) Plastic Fittings for Polyethylene (PE) Plastic Pipe and Tubing
5. ASTM D3350 Standard Specification for Polyethylene Plastics Pipe and Fittings Materials
6. ASTM F905 Standard Practice for Qualification of Polyethylene Saddle-Fused Joints
7. ASTM F1041 Standard Guide for Squeeze-off of Polyolefin Gas Pressure Pipe and Tubing
8. ASTM F1055 Standard Specification for Electrofusion Type Polyethylene Fittings for Outside Diameter Controlled Polyethylene Pipe and Tubing
9. ASTM F1200 Standard Practice for Electrofusion Joining Polyolefin Pipe and Fittings
10. ASTM F1583 Standard Specification for Tools to Squeeze-off Polyethylene (PE) Gas Pipe or Tubing
11. ASTM F1668 Standard Guide for Construction Procedures for Buried Plastic Pipe
12. ASTM F2104 Standard Practice for Field Leak Testing of Polyethylene (PE) Pressure Piping Systems Using Hydrostatic Pressure
13. ASTM F2206 Standard Specification for Fabricated Fittings of Butt-Fused Polyethylene (PE) Plastic Pipe, Fittings, Sheet Stock, Plate Stock, or Block Stock
14. ASTM F2620 Standard Practice for Heat Fusion Joining of Polyethylene Pipe and Fittings
15. ASTM F2786 Standard Practice for Field Leak Testing of Polyethylene (PE) Pressure Piping Systems Using Gaseous Testing Media Under Pressure (Pneumatic Leak Testing)
16. ASTM F2880 Standard Specification for Lap-Joint Type Flange Adapters for Polyethylene Pressure Pipe in Nominal Pipe Sizes 34 in. to 65 in.
17. ASTM F3124 Standard Practice for Data Recording the Procedure used to Produce Heat Butt Fusion Joints in Plastic Piping Systems or Fittings
18. ASTM F3183 Standard Practice for Guided Side Bend Evaluation of Polyethylene Pipe Butt Fusion Joint
19. ASTM F3190 Standard Practice for Heat Fusion Equipment (HFE) Operator Qualification on Polyethylene (PE) and Polyamide (PA) Pipe and Fittings



## GIS - EBMUD Electrofusion Third Party Inspection

- Initiated in 2019
- Inspector on-site during fusion activities to document
  - Adequacy of tooling
  - Verify Qualification of Fusion Technician
  - Adherence to fusion procedures
  - Witness pressure testing (sidewall) prior to tapping
- Provide records for each electrofusion based on geospatial location (service address or pipeline station)



Cloud Mapping Product To Track EF Fitting Installations



## Capture Critical GIS Information Before and During Installation (Traceability)

- Population of GIS Attributes for all installed Features (components)
  - Feature Class (pipe, fitting, etc.)
  - Diameter
  - Material
  - Pressure Class
  - Manufacturer
  - Date Installed
  - Installation Technician Name/Qualification
  - Fusion Record
  - Location (GPS coordinates)
  - Pressure Test(s) Record(s)
- Allow future generations to make analytical decisions of what to replace/increase maintenance activity based on:
  - Specific material performance
  - Individual component performance
  - Mandated material replacement
  - Manufacturer recalls
  - Failure/repair rates associated with identical/similar GIS Features



# Thank You for Attending

## Questions

Greg Scoby, PE

Crossbore Consultants

[Gregs@crossboreconsultants.com](mailto:Gregs@crossboreconsultants.com)